



RECEIVED

FEB 25 2020

- CONSULTANTS
- ENVIRONMENTAL
- GEOTECHNICAL
- MATERIALS
- FORENSICS

February 21, 2020

NE Dept of Environment and Energy
By: _____ Front Desk _____

Air Quality Compliance
Nebraska Department of Environmental and Energy
Suite 400, The Atrium Building
1200 N Street
Lincoln, NE 68509-8922

**Subject: Test Protocol for Gasifier/Thermal Oxidizer Air Emissions Testing
AltEn, LLC – Mead, Nebraska
AET Project No. 14-20298**

To Whom it may Concern:

On behalf of AltEn, LLC, American Engineering Testing, Inc. is resubmitting the above titled test protocol for the emissions testing at the facility located in Mead, NE.

The testing has been scheduled for March 25, 2020 with March 26, 2020 reserved for contingency.

If you have any questions or comments, please feel free to contact me at (651) 603-6611.

Sincerely,

Austin J. Lesmeister
Manager
Environmental Field Department

Enc: Test Protocol

cc: Mr. Brad Anderson – AltEn, LLC
Mr. Ken Peterson – AltEn, LLC
Mr. Scott Tinglehoff – AltEn, LLC





AMERICAN
ENGINEERING
TESTING, INC.

CONSULTANTS
• ENVIRONMENTAL
• GEOTECHNICAL
• MATERIALS
• FORENSICS

Test Protocol for Gasifier/Thermal Oxidizer Air Emissions Testing

AltEn, LLC

1344 County Road 10

Mead, Nebraska 68041

Facility ID Nos. 084069, 111532

AET Project No. 14-20298

Date:

February 21, 2020

Proposed Test Date:

March 25, 2020

Prepared for:

Mr. Brad Anderson
AltEn, LLC
1344 County Road 10
Mead, Nebraska 68041

Prepared By:

American Engineering Testing, Inc.
550 Cleveland Avenue North
Saint Paul, Minnesota 55114

www.amengtest.com



TABLE OF CONTENTS
AET PROJECT No. 14-20298

PART I. GENERAL INFORMATION 1

PART II. TESTING REQUIREMENTS 2

PART III. OPERATING CONDITIONS 2

PART IV. TEST METHODS AND LOCATIONS 2

PART V. SCHEDULES 3

APPENDIX

A. Field Data Sheets

PART I. GENERAL INFORMATION

1. Name and address of emission facility:

AltEn, LLC
1344 County Road 10
Mead, Nebraska 68041

Contact Mr. Brad Anderson
Phone No: (402) 624-2000 ext. 1010
E-Mail: banderson@mrgkc.com

2. Reason the emission units are to be tested:

Testing is being conducted to comply with NDEE Administrative Compliance Order No. 3469 to generate emission factors for VOC, HAP, CO and PM₁₀.

3. Physical description of the emission unit to be tested:

Gasifier/Thermal Oxidizer – Distillers grains are fed from the adjacent ethanol production facility into a gasifier. The gasifier removes moisture and gases from the solids, leaving an activated carbon charcoal. The exhaust gases are routed to a thermal oxidizer for emission control.

Testing will be conducted on the following emission point:

4. Name of independent testing company, contact person and telephone number:

American Engineering Testing, Inc
550 Cleveland Avenue North
St. Paul, MN 55114

Contact: Austin J. Lesmeister
Phone No: (651)-603-6611
E-Mail: alesmeister@amengtest.com

5. Safety precautions and personal protective equipment:

AltEn, LLC requires the use of hard hats, steel-toed footwear, hearing protection and safety glasses while in all production areas.

PART II. TESTING REQUIREMENTS

1. The following is a description of the source and pollutants to be tested, the applicable emission limits, rules or regulations, and test methodologies for each:

| Emission Unit No. | Limitation Basis of Pollutant Tested | Pollutant Tested and Applicable Emission Limit | Specific Methods/Procedures Required Citation |
|---------------------------|---|---|---|
| GASIFIER/THERMAL OXIDIZER | NDEE Administrative Compliance Order 3469 | PM/PM ₁₀ /PM _{2.5} ⁽¹⁾ | EPA Methods 1-4 and 5/202 |
| | | CO | EPA Methods 1-4 and 10 |
| | | VOC/HAP | EPA Methods 1-4, 18 and NCASI 94.02 |

(1) Total PM will be used as a surrogate for PM₁₀ and PM_{2.5}.

PART III. OPERATING CONDITIONS

1. The following contains a detailed description of the operating conditions for each emission unit to be tested including the specific time interval, process rates, operating capacity, control device parameters, and other special operating conditions:

Gasifier/Thermal Oxidizer

| |
|---|
| Process equipment description for units to be tested: Gasifier producing biochar from DDGS received from adjacent ethanol facility |
| Process equipment parameter monitoring during performance test: Operating condition: Normal, approximate maximum of 14 Tons per day Process rates: Product Manufactured, Tons per Day |
| Control equipment description: Thermal Oxidation |
| Control Equipment Operating Parameter During Test: Thermal Oxidizer Chamber Temperature, °F |

2. The approximate maximum process rates for each emission unit are listed in the previous tables. The average/normal process and operating rates will be verified onsite and included in the final report.

PART IV. TEST METHODS AND LOCATIONS

1. The following is description of the methods, number of test runs and length of test runs for determination of air emissions:

A. Volumetric Airflow Measurement:

- EPA Method 1 for the location of sampling ports and traverse points. Stack measurements will be verified on-site. The absence of cyclonic flow will be verified for all locations. Stack schematics will be provided in the final report.

- EPA Method 2 for velocity and volumetric flow rate. One measurement will be conducted at the outlet during each run.
- EPA Method 3A will be performed for the determination of stack gas molecular weight. Three, sixty-minute test runs will be conducted.
- EPA Method 4 for the determination of stack gas moisture. The large impinger technique will be employed.

B. Total PM/PM₁₀ Concentrations:

- EPA Methods 5 or 17 and 202 will be performed for determination of particulate matter. A minimum of three, 60-minute test runs will be conducted. EPA Method 202 will only be performed if the stack temperature exceeds 85°F.

C. Carbon Monoxide Concentrations:

- EPA Method 10 will be conducted for the instrumental determination of carbon monoxide concentration. Three, 60-minute runs will be performed.

D. VOC/HAP Concentrations:

- Modified NCASI 94.02/EPA Method 18 for the determination of acetaldehyde, acrolein, ethanol, ethyl acetate, formaldehyde, formic acid, isoamyl alcohol, and methanol for the calculation of VOC and HAP emissions. The sum of the detected and undetected speciated VOC/HAP will be used to determine the VOC/HAP mass emission rate. One spiked sample will be collected to verify QC standards for the method. Three, sixty-minute test runs will be conducted.

2. The following identifies proposed deviations from EPA methods:

A. VOC/HAP Concentrations

- EPA Method 18/NCASI CI/SG/PULP- 94.02 will be modified as follows:
 - Acetaldehyde and acrolein samples will be collected in Tedlar bags with an iced condensate knockout impinger located prior to the bag. The knockout impinger will be analyzed only if a quantifiable amount of liquid is obtained.
 - Formaldehyde will be analyzed using UV Spectrophotometric techniques.

PART V. SCHEDULES

1. Testing is anticipated to be conducted according to the following schedule:

| | |
|-----------------------------|----------------------------|
| Wednesday March 25, 2020 | Thursday March 26, 2020 |
| Compliance Testing | Contingency Day |

2. Two copies of the comprehensive test report will be submitted to the Nebraska Department of Environmental and Energy (NDEE) within 35 days after the date of the test.

Appendix A

Field Data Sheets



**AMERICAN
ENGINEERING
TESTING, INC.**

EPA Method 2
(Except where noted)

Page ____ of ____

| | |
|--------------|-----------------|
| Client Name: | Project Title: |
| Contact: | Project Number: |
| Unit Tested: | Test Location: |

| Test Data | | | | | | | | | Stack/Duct Information |
|-------------------------------|------------|-----------|------------|------------|------------|------------|------------|------------|---------------------------|
| Test Time | | | | | | | | | Configuration: |
| Test Date | | | | | | | | | Orientation: |
| Pitot Tube Leak Check | | | | | | | | | |
| Ambient Pressure in. Hg | | | | | | | | | Dimensions in: |
| Static Pressure in. H2O | | | | | | | | | A Distance in.: |
| Pitot Tube Coefficient, C_p | | | | | | | | | B Distance in.: |
| O ₂ % (Method) | | | | | | | | | Port Dia. in: |
| CO ₂ % (Method) | | | | | | | | | Port Length in: |
| Wet Bulb °F (EPA Method 4) | | | | | | | | | Traverse Points: |
| Dry Bulb °F (EPA Method 4) | | | | | | | | | Traverse Matrix: |
| No. | T-Ins. in. | a° | Δp | Δp | Δp | Δp | Δp | Δp | Conducted By: |
| | | | | | | | | | Equipment Information |
| | | | | | | | | | Manometer ID: |
| | | | | | | | | | Thermometer ID: |
| | | | | | | | | | Thermocouple ID: |
| | | | | | | | | | Thermocouple ID: |
| | | | | | | | | | Pitot Tube ID: |
| | | | | | | | | | Barometer ID: |
| | | | | | | | | | <u>Schematic of Stack</u> |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| Average: | | | ---- | | ---- | | ---- | | |



**AMERICAN
ENGINEERING
TESTING, INC.**

**EPA METHOD 3A
ANALYZER MONITORING
DATA SHEET**

| | |
|-----------------|--|
| Client Name: | Project Title: |
| Project Number: | Client Contact: |
| Test Location: | Test Number: Test Date: Duct Diameter: |

| Calibration Gas Composition | Cylinder No. | Cylinder Values | | Test Times: |
|---|--------------|--------------------|---------------------|-------------|
| | | O ₂ [%] | CO ₂ [%] | |
| Zero Nitrogen | | | | Run #1 |
| High-Level Span O ₂ /CO ₂ in N ₂ | | | | Run #2 |
| Mid-Level Span O ₂ /CO ₂ in N ₂ | | | | Run #3 |

| O ₂ Analyzer System | | Calibration Time, hr: | | CO ₂ Analyzer System | | Calibration Time, hr: | |
|--------------------------------|--|-----------------------------------|--|---------------------------------|--|------------------------------------|--|
| O ₂ Analyzer ID #: | | O ₂ Analyzer Range, %: | | CO ₂ Analyzer ID #: | | CO ₂ Analyzer Range, %: | |

| O ₂ Analyzer Calibration | Cylinder Value, % | Analyzer Response, % | Absolute Difference, % | Difference, % of Span | CO ₂ Analyzer Calibration | Cylinder Value, % | Analyzer Response, % | Absolute Difference, % | Difference, % of Span |
|-------------------------------------|-------------------|----------------------|------------------------|-----------------------|--------------------------------------|-------------------|----------------------|------------------------|-----------------------|
| Zero Gas, % | | | | | Zero Gas, % | | | | |
| High-Level Span, % | | | | | High-Level Span, % | | | | |
| Mid-Level Span, % | | | | | Mid-Level Span, % | | | | |

| System Bias Check | Cylinder Value, % | System Response, % | Absolute Difference, % | Difference, % of span | System Bias Check | Cylinder Value, % | System Response, % | Absolute Difference, % | Difference, % of span |
|-------------------|-------------------|--------------------|------------------------|-----------------------|-------------------|-------------------|--------------------|------------------------|-----------------------|
| Zero Gas, % | | | | | Zero Gas, % | | | | |
| Upscale Gas, % | | | | | Upscale Gas, % | | | | |

| Stratification Test Time, hrs: | O ₂ %, 1 min average | O ₂ %, Deviation from Mean | CO ₂ %, 1 min average | CO ₂ %, Deviation from Mean | Result: | Response Test | | | |
|--------------------------------|---------------------------------|---------------------------------------|----------------------------------|--|--|--------------------------|---------------------------|---------------------|--|
| | Diameter x 0.167, in | | | | | O ₂ Time, sec | CO ₂ Time, sec | Response Time, sec: | |
| Diameter x 0.500, in | | | | | Zero Gas to High Span High Span to Zero Gas | | | | |
| Diameter x 0.833, in | | | | | | | | | |

| System Drift Checks | Time, Hrs | Initial System Response, % | Final System Response, % | Post Run System Drift, % of Span | System Performance, % of Span | System Drift Checks | Time, Hrs | Initial System Response, % | Final System Response, % | Post Run System Drift, % of Span | System Performance, % of Span |
|---------------------|-----------|----------------------------|--------------------------|----------------------------------|-------------------------------|---------------------|-----------|----------------------------|--------------------------|----------------------------------|-------------------------------|
| Zero Gas, % | | | | | | Zero Gas, % | | | | | |
| Upscale Gas, % | | | | | | Upscale Gas, % | | | | | |
| Zero Gas, % | | | | | | Zero Gas, % | | | | | |
| Upscale Gas, % | | | | | | Upscale Gas, % | | | | | |
| Zero Gas, % | | | | | | Zero Gas, % | | | | | |
| Upscale Gas, % | | | | | | Upscale Gas, % | | | | | |
| Zero Gas, % | | | | | | Zero Gas, % | | | | | |
| Upscale Gas, % | | | | | | Upscale Gas, % | | | | | |
| Zero Gas, % | | | | | | Zero Gas, % | | | | | |
| Upscale Gas, % | | | | | | Upscale Gas, % | | | | | |

| | | |
|---|--|--|
| Analyzer Calibration Error = $\frac{\text{Analyzer Response} - \text{Cylinder Value}}{\text{Span}} \times 100$ Criteria ≤ 2% of Span or ≤ 0.5% (whichever is larger) | Pre-Run System Bias = $\frac{\text{System Response} - \text{Cylinder Value}}{\text{Span}} \times 100$ Criteria ≤ 5% of Span or ≤ 0.5% (whichever is larger) | Post-Run System Bias and Drift = $\frac{\text{Final System Response} - \text{Initial System Response}}{\text{Span}} \times 100$ Criteria ≤ 5% of Span or ≤ 0.5% (whichever is larger) Recalibration Required if System Drift ≥ 3%. |
|---|--|--|

| | | |
|--------------------|---|------------------|
| Form Completed by: | Date Completed: | Present on Site: |
| Data Reviewed by: | American Engineering Testing, Inc 550 Cleveland Ave N. St. Paul, MN 55114 | REV - 041217 |



**AMERICAN
ENGINEERING
TESTING, INC.**

**EPA METHOD 10
ANALYZER MONITORING
DATA SHEET**

| | | | | | | | | | | | | | |
|---|--|---------------------------------------|---|---|----------------------------------|-------------------------------------|---------------------------------|---|---------------------------------------|---|---|----------------------------------|-------------------------------|
| Client Name: | | | | Project Title: | | | | | | | | | |
| Project Number: | | | | Client Contact: | | | | | | | | | |
| Test Location: | | | | Test Number: | | Test Date: | | Duct Diameter: | | | | | |
| Calibration Gas Composition | | Cylinder No. | | Cylinder Values CO [ppm _{v,d}] | | Test Times: | | | | | | | |
| Zero Nitrogen | | | | | | Run #1 | | | | | | | |
| High-Level Span CO in N ₂ | | | | | | Run #2 | | | | | | | |
| Mid-Level Span CO in N ₂ | | | | | | Run #3 | | | | | | | |
| CO Analyzer System | | | Calibration Time, hr: | | CO Analyzer System | | | Calibration Time, hr: | | | | | |
| CO Analyzer ID #: | | | CO Analyzer Range [ppm _v]: | | CO Analyzer ID #: | | | CO Analyzer Range [ppm _v]: | | | | | |
| CO Analyzer Calibration | | Cylinder Value, ppm _{v,d} | Analyzer Response, ppm _{v,d} | Absolute Difference, ppm _{v,d} | Difference, % of Span | CO Analyzer Recalibration | | Cylinder Value, ppm _{v,d} | Analyzer Response, ppm _{v,d} | Absolute Difference, ppm _{v,d} | Difference, % of Span | | |
| Zero Gas, ppm _{v,d} | | | | | | Zero Gas, ppm _{v,d} | | | | | | | |
| High-Level Span, ppm _{v,d} | | | | | | High-Level Span, ppm _{v,d} | | | | | | | |
| Mid-Level Span, ppm _{v,d} | | | | | | Mid-Level Span, ppm _{v,d} | | | | | | | |
| System Bias Check | | Cylinder Value, ppm _{v,d} | System Response, ppm _{v,d} | Absolute Difference, ppm _{v,d} | Difference, % of span | System Bias Check | | Cylinder Value, ppm _{v,d} | System Response, ppm _{v,d} | Absolute Difference, ppm _{v,d} | Difference, % of span | | |
| Zero Gas, ppm _{v,d} | | | | | | Zero Gas, ppm _{v,d} | | | | | | | |
| Upscale Gas, ppm _{v,d} | | | | | | Upscale Gas, ppm _{v,d} | | | | | | | |
| Stratification Test | | CO ppm _{v,d} , 1 min average | | CO Deviation from Mean | | Result: | | Response Test | | | | | |
| Time, hrs: | | | | | | | | Time, sec | | Response Time, sec: | | | |
| Diameter x 0.167, in | | | | | | | | Zero Gas to High Span | | | | | |
| Diameter x 0.500, in | | | | | | | | High Span to Zero Gas | | | | | |
| Diameter x 0.833, in | | | | | | | | | | | | | |
| System Drift Checks | | Time, Hrs | Initial System Response, ppm _{v,d} | Final System Response, ppm _{v,d} | Post Run System Drift, % of Span | System Performance, % of Span | System Drift Checks | | Time, Hrs | Initial System Response, ppm _{v,d} | Final System Response, ppm _{v,d} | Post Run System Drift, % of Span | System Performance, % of Span |
| Zero Gas, ppm _{v,d} | | | | | | | Zero Gas, ppm _{v,d} | | | | | | |
| Upscale Gas, ppm _{v,d} | | | | | | | Upscale Gas, ppm _{v,d} | | | | | | |
| Zero Gas, ppm _{v,d} | | | | | | | Zero Gas, ppm _{v,d} | | | | | | |
| Upscale Gas, ppm _{v,d} | | | | | | | Upscale Gas, ppm _{v,d} | | | | | | |
| Zero Gas, ppm _{v,d} | | | | | | | Zero Gas, ppm _{v,d} | | | | | | |
| Upscale Gas, ppm _{v,d} | | | | | | | Upscale Gas, ppm _{v,d} | | | | | | |
| Zero Gas, ppm _{v,d} | | | | | | | Zero Gas, ppm _{v,d} | | | | | | |
| Upscale Gas, ppm _{v,d} | | | | | | | Upscale Gas, ppm _{v,d} | | | | | | |
| Zero Gas, ppm _{v,d} | | | | | | | Zero Gas, ppm _{v,d} | | | | | | |
| Upscale Gas, ppm _{v,d} | | | | | | | Upscale Gas, ppm _{v,d} | | | | | | |
| Analyzer Calibration Error = | | | | Pre-Run System Bias = | | | | Post-Run System Bias and Drift = | | | | | |
| $\frac{\text{Analyzer Response} - \text{Cylinder Value}}{\text{Span}} \times 100$ | | | | $\frac{\text{System Response} - \text{Cylinder Value}}{\text{Span}} \times 100$ | | | | $\frac{\text{Final System Response} - \text{Initial System Response}}{\text{Span}} \times 100$ | | | | | |
| Criteria ≤ 2% of Span or ≤ 0.5 ppm (whichever is larger) | | | | Criteria ≤ 5% of Span or ≤ 0.5 ppm (whichever is larger) | | | | Criteria ≤ 5% of Span or ≤ 0.5 ppm (whichever is larger) Recalibration Required if System Drift ≥ 3% | | | | | |
| Form Completed by: | | | Date Completed: | | | Present on Site: | | | | | | | |
| Data Reviewed by: | | | American Engineering Testing, Inc 550 Cleveland Ave N. St. Paul, MN 55114 | | | REV - 041217 | | | | | | | |



**AMERICAN
ENGINEERING
TESTING, INC.**

**EPA METHOD 25A
ANALYZER MONITORING
DATA SHEET**

Client Name: _____ Project Title: _____
Project Number: _____ Client Contact: _____

Test Location: _____ Test Number: _____ Test Date: _____ Duct Diameter: _____

| Calibration Gas Composition | Cylinder No. | Cylinder Value | Test Times: | Sample Line Length, ft. |
|--|--------------|----------------|-------------|-------------------------|
| Zero Air, ppm _v | | | Run #1 | Sample Line Temp, °F |
| High Span Propane in Air, ppm _v | | | Run #2 | Response Test #1, sec |
| Mid Span Propane in Air, ppm _v | | | Run #3 | Response Test #2, sec |
| Low Span Propane in Air, ppm _v | | | | Response Test #3, sec |
| | | | | Response Time, sec: |

| THC Analyzer System: | | | | Time, hr: | THC Analyzer System Cal #2: | | | | Time, hr: |
|-----------------------------|--|-----------------------------------|---------------------------------------|-----------------------------|--|----------------------------------|-----------------------------------|---------------------------------------|-----------------------------|
| THC Analyzer ID #: | THC Analyzer Range, ppm _v : | | | THC Analyzer ID #: | THC Analyzer Range, ppm _v : | | | | |
| System Calibration | Cylinder Value, ppm _v | System Response, ppm _v | Absolute Difference, ppm _v | Difference, % of Cyl. Value | System Calibration | Cylinder Value, ppm _v | System Response, ppm _v | Absolute Difference, ppm _v | Difference, % of Cyl. Value |
| Zero Gas, ppm _v | | | | | Zero Gas, ppm _v | | | | |
| High Span, ppm _v | | | | | High Span, ppm _v | | | | |
| Mid Span, ppm _v | | | | | Mid Span, ppm _v | | | | |
| Low Span, ppm _v | | | | | Low Span, ppm _v | | | | |

| System Drift Checks | Time, hrs | Initial System Response, ppm _v | Final System Response, ppm _v | System Drift, % of Span | System Drift Checks | Time, hrs | Initial System Response, ppm _v | Final System Response, ppm _v | System Drift, % of Span |
|-------------------------------|-----------|---|---|-------------------------|-------------------------------|-----------|---|---|-------------------------|
| Zero Gas, ppm _v | | | | | Zero Gas, ppm _v | | | | |
| Upscale Gas, ppm _v | | | | | Upscale Gas, ppm _v | | | | |
| Zero Gas, ppm _v | | | | | Zero Gas, ppm _v | | | | |
| Upscale Gas, ppm _v | | | | | Upscale Gas, ppm _v | | | | |
| Zero Gas, ppm _v | | | | | Zero Gas, ppm _v | | | | |
| Upscale Gas, ppm _v | | | | | Upscale Gas, ppm _v | | | | |
| Zero Gas, ppm _v | | | | | Zero Gas, ppm _v | | | | |
| Upscale Gas, ppm _v | | | | | Upscale Gas, ppm _v | | | | |
| Zero Gas, ppm _v | | | | | Zero Gas, ppm _v | | | | |
| Upscale Gas, ppm _v | | | | | Upscale Gas, ppm _v | | | | |
| Zero Gas, ppm _v | | | | | Zero Gas, ppm _v | | | | |
| Upscale Gas, ppm _v | | | | | Upscale Gas, ppm _v | | | | |

| | |
|---|--|
| Analyzer Calibration Error = $\frac{\text{System Response} - \text{Cylinder Value}}{\text{Span}} \times 100$ Criteria ≤ 5% of Cylinder Value | System Drift = $\frac{\text{Final System Response} - \text{Initial System Response}}{\text{Span}} \times 100$ Criteria ≤ 3% of Span |
|---|--|

Form Completed by: _____ Date Completed: _____ Present on Site: _____
Data Reviewed by: _____ American Engineering Testing, Inc 550 Cleveland Ave N. St. Paul, MN 55114 REV - 041217

Speciated VOC Sampling Data

Client Name - City, State
 Name of Unit Tested
 AET #14-XXXXX

| | |
|---|--------------------------------|
| Run Number: Test Date: Start Time, hrs: Duration, min: Test Method: Meter Box ID: Stack Thermocouple ID: DGM Correction Factor: Probe Material: Probe Temp. °F: Filter Temp. °F: Ambient Pressure, in. Hg: | 60 NCASI/Modified Method 18 |
|---|--------------------------------|

| Time, hrs. | Dry Gas Meter Reading, L | Vacuum In. Hg | Probe Temp. °F | Filter Temp. °F | Meter IN Temp. °F | Meter OUT Temp. °F | Stack Temp. °F |
|------------|--------------------------|---------------|----------------|-----------------|-------------------|--------------------|----------------|
| | | --- | --- | --- | --- | --- | --- |
| Average: | | | | | | | |

| Train Data | Compound | Mass Collected, ug | Flow Rate, DSCFM | Rate, Lbs/Hr |
|------------|----------|--------------------|------------------|--------------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Total, lbs/hr:

| Leak Test Parameters | Result | Test Parameters | Result |
|-------------------------|--------|------------------------------------|------------|
| Initial DGM Reading: | | Test Run Duration, min: | |
| Final DGM Reading: | | Volume Metered, L: | |
| Duration, min: | | DGM Absolute Temperature, °R: | |
| Leak Rate, LPM: | | Volume Metered, DSL: | |
| Max Leak Rate, LPM: | | Volume Metered, DSM ³ : | |
| Test Result, Pass/Fail: | | Volume Metered, DSCF: | |
| Form Completed by: | | Date Completed: | |
| Data Reviewed by: | | | REV-010715 |